

c/83

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2024/ GH | 695

Dated:-20/11/2024

To

The Manager  
M/s Hotel Paradise Dx.  
3518, Dariba Pan, Pahar Ganj,  
New Delhi

Sub: Regarding issuance of FSC in r/o M/s Hotel Paradise Dx., 3518, Dariba Pan, Pahar Ganj, New Delhi.

Sir,

This has reference to online id no. 2024102215984 dated 22/10/24, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 14/11/24 in the presence of **Mr. Alam** and following shortcomings were observed:-

1. Hose reel & pump found nonfunctional.
2. Pump is not provided with auto mode start provision.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to :-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.