

C/59

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/697 .

Dated:-21/11/2024

To,  
The Manager,  
M/S Krishna Plaza Guest House  
Plot No. 1, Block 80-A, Krishna Market,  
Main Bazar, Pahar Ganj, New Delhi.

**Sub: Regarding renewal of FSC in r/o M/S Krishna Plaza Guest House located at Plot No. 1, Block 80-A, Krishna Market, Main Bazar, Pahar Ganj, New Delhi.**

Sir,

This has reference to your online ID No. 2024102416095 dated 24/10/24, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 13/11/24 in presence of Mr. Lalit Mittal and following shortcomings were observed:

1. Hose reel found non functional.
2. Exhaust fan found nonfunctional.
3. Pump not provided.
4. Further, use of stilt floor shall also be clarified so that occupancy can be ascertained accordingly.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.