

Frequent hand sanitization-wearing face mask-keep physical distance to prevent Covid-19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F. 6. / DFS / MS / BP / 2024/ 634

Dated: 25/11/2024

To,

The Executive Engineer -I (Bldg.)HQ, Municipal Corporation of Delhi, 9th Floor, Civic Centre, Minto Road, New Delhi – 110002.

Subject: Online building plans in r/o Addition / Alteration in r/o Plot No. 01, Block – B, Pocket-10, Sector- 13, Dwarka, New Delhi – 110078.

Sir,

Please refer your online ID No. 10119719 dated 15-11-2024 on the subject cited above. In this connection it is to inform you that the referred online building plans have been scrutinized from fire/life safety point of view and observed following short comings:

- 1. Protection of steel staircase is not proposed.
- 2. One staircase, serving from basement is not segregated on stilt floor by slab.
- 3. Width of door is not equal to the width of staircase.
- 4. Width of landing is lesser than the width of staircase.
- 5. Smoke venting is not proposed.

Therefore, the proposal is rejected.

(ATIN CARC)

Ph.: 011-23414000