

c/101

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2024/690

Dated: 18/11/2024

To,

The Manager,
Tourist Bungalow Guest House,
9398/10 Multani Dhanda, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Tourist Bungalow Guest House at 9398/10, Multani Dhanda, Pahar Ganj, New Delhi.

Sir,

This has reference to on line ID No. 2024092714914 dated 26/10/24, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 12/11/24 in the presence of Mr. Satish and following shortcomings were observed: -

1. FCD is not provided as no. of beds per floor is more than 10.
2. PA system found nonfunctional
3. Smoke management system found nonfunctional.
4. Pump not in auto start mode.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:

Addl. Commissioner of Police (Lic), 1st floor, Defence Colony Police Station, New Delhi.