



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Mixed/2024/SZ/ 641

Dated: 26/11/2024

To

Sh. Narender Kumar Gaur,  
Fire Officer, NDMC,  
Mezzanine Floor, Sansad Marg,  
Palika Kendra, New Delhi-110001

**Sub: Regarding renewal of Fire Safety Certificate in r/o "Lok Kalyan Bhawan" located at Khan Market, New Delhi-110003**

Sir,

This is with reference to your email dated 20/09/2024. In this connection, the premise was re-visited by the officer concerned of this department on dated 14/11/2024 to verify the compliance of shortcomings communicated vide this office letter No. F.6/DFS/MS/Mixed/SZ/2020/1881 dated 28/07/2020 in your presence. During the inspection, the following shortcomings are observed.

1. Fire Check Door found removed from stairs as well as basement.
2. Electrical shaft found unsealed in B Wing.
3. First Aid hose-reel found non-functional in A Wing.
4. Yard hydrant hose-boxes found empty.
5. Exit signages found removed at 9<sup>th</sup> floor.
6. Domestic LPG cylinder being used in kitchen at 9<sup>th</sup> floor.
7. 5<sup>th</sup>, 10<sup>th</sup> & 11<sup>th</sup> Floor in C Wing found locked and hence, could not be checked.
8. Renovation work was under progress at 7<sup>th</sup> floor in B Wing.

In view of the above shortcomings, the application for renewal of fire safety certificate is rejected. The occupancy of the building/premises in the absence of requisite fire safety measures shall be at risk and liability of the management.

Yours faithfully,

  
(AJUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (Bldg.), N.D.M.C, Palika Kendra, New Delhi-110001