

C-106

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/Hospital/2024/SZ/ 638

Dated: 25/11/2024

To,

The Medical Superintendent,  
M/s Rao Tula Ram Memorial Hospital,  
Jaffarpur, New Delhi-110073.

Sub: - Regarding renewal of Fire Safety Certificate in r/o. M/s Rao Tula Ram Memorial Hospital situated at Jaffarpur, New Delhi-110073.

Sir,

This has reference to your Letter No. Form 'J' dated Nil, on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the hospital building on dated 14.11.2024 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Dr. Anil Yadav (CMO) & Sh. Sita Ram Meen (PWD) was present and it was observed that the hospital building is comprised of ground plus two upper floors and have following shortcomings.

1. Four Porta Cabins constructed at roof of first floor needs to be removed.
2. Passage found blocked in front of OT.
3. Staircases found blocked near wards.
4. Fire-fighting system may be extended to Oxygen plant and manifold room.

Keeping in view of above, renewal of Fire Safety Certificate can-not be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully,

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. MS, Nursing Homes, DGHS, Govt of NCT of Delhi, S-1, 3<sup>rd</sup> Floor, School Block, Shakarpur, Delhi-110092.