

6151

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2024/ 791

Dated: - 28/11/2024

To,
The Manager,
Govt. Co-ed Sr. Sec. School,
Jharoda Kalan, New Delhi-110072.

Sub: - Regarding renewal of FSC from fire safety point of view in r/o Govt. Co-ed Sr. Sec. School at Jharoda Kalan, New Delhi-110072.

Sir,

Please refer to your letter No. GGSSS/JHK/2024/294 dated 03.10.2024, on the subject cited above. In this connection it is to inform you that the above said school building have been inspected by the officer concerned of this department, in presence of Dr. Neelam Rani (Principal) on dated 14.11.2024, to check the status of the shortcomings already pointed out by this department vide letter No. F6/DFS/MS/School/2024/SZ/566 dated 29.08.2024. During the course of inspection, it was observed that the shortcomings are found complied except shortcoming No. 1. The classes running in 25 porta cabins at ground floor.

In view of the above, renewal of 'Fire Safety Certificate' cannot be considered at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully


(Anil Garg)
Director
Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.


-for necessary action

cuu

duw

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 566

Dated: 29/08/2024

To,
 The Princiapl,
 Govt. Girls Sr. Sec. School,
 Jharoda Kalan, New Delhi- 110072.

Sub: - Regarding renewal of "FSC" from fire safety point of view in r/o Govt. Girls Sr. Sec. School at Jharoda Kalan, New Delhi- 110072.

Sir,
 Please refer to your letter No. GGSSS/JHK/2024 dated Nil received through office outdoor dairy No. 44941 dated 24.07.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 20.08.2024 in the presence of Dr. Neelam Rani (Principal), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school building comprised of basement, ground plus three upper floors and it has come in notice that the classes running in 25 Porta cabins at ground floor. Therefore, following shortcomings were observed: -

1. The classes running in 25 porta cabins at ground floor.
2. Hose reels/hydrant system provided but found not functional
3. Terrace fire pump of 450 LPM provided but found not functional.
4. Exit signage's are found removed.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

 (Atul Garg)
 Director
 Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
: - for necessary action please.
2. Executive Engineer (Bldg.), MCD, 9th floor, Civic Centre, Minto Road, New Delhi- 02.
: - for information please.

21/8/24
 4/10/24