



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

Dated: 28/11/2024

No. F6/DFS/MS/School/NDZ/2024/ 792

To,
The Principal,
Little Flowers Public Sr. Sec. School
Shivaji Park, Shahdara, Delhi - 110032.

Sub: - Regarding grant of Fire Safety Certificate in r/o Little Flowers Public Sr. Sec. School located at Shivaji Park, Shahdara, Delhi - 110032.

Sir,

This has a reference to Outdoor diary no. 8115 dated 22/10/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 16/11/2024 in the presence of Mrs. Neeta Dua (Principal), and observed that earlier building comprised of Ground plus three floors and now building comprised of **ground plus four upper floors**, hence this is the case of **addition/alteration** and following shortcomings were observed during time of inspection:

1. Over head water storage tank of 10,000 liters capacity required instead of 4,000 liters.
2. Exit Signage found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, B- Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Little Flowers Public Sr. Sec. School located at Shivaji Park, Shahdara, Delhi - 110032.