

c/26



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 790

Dated: 28/11/2024

To

The Principal
M.C. Primary Boys School,
Adarsh Nagar No.1, Delhi-33.

Sub: Regarding issues of fire safety certificate in r/o M.C. Primary Boys School/Nigam Pratibha Vidyalaya (School ID No-1253047/48) at Adarsh Nagar, Delhi-110033.

Sir,

This has reference to your letter no. nil dated 01.11.2024 received in this department vide outdoor dairy no.8520 dated 04.11.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 22.11.2024 to verify the fire safety arrangements provided therein as per the NBC Part-IV/UBBL-2016. At the time of inspection Sh. Omparkash (Incharge) was also present at site and said building was comprised of 02 blocks, one block comprised of ground plus 03 upper floors & 2nd block comprised of ground plus first floors. Your request for FSC is rejected under Rule 35 due to following shortcomings.

1. There is one staircase provided width of 1.50m continues from ground to first floor only needs continues from ground to terrace level (B-block, ground & first floor).
1. Fire extinguishers provided is 05 nos. against the requirement of 15 nos.
2. Hose reel hose is provided but not functional and damaged condition.
3. Terrace level fire pump capacity of 450 LPM is not provided.
4. Terrace level fire water tank capacity of 10,000ltr is not provided.
5. Exit & floors signage's not provided at strategic location in the school building.
6. Standby power supply is not provided.
7. Electrical panel below in staircase needs to be removed/shifted in a safer place.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.