

c/28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI- 110001

No. F.6/DFS/MS/School/2024/SZ/ 795

Dated: 28/11/2024

To

The Principal
New Green Field School,
Alaknanda (Kalkaji) Near Tara Apartment,
New Delhi-110019

Sub: Regarding renewal of FSC in r/o M/s New Green Field School, Alaknanda (Kalkaji) Near Tara Apartment, New Delhi-110019

Sir,

This has reference to your letter no. NGFS/FS/24/2024/219 dated 30/09/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 25.11.2024 in the presence of Ms. Nidhi Chauhan (Principal) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel provided but found nonfunctional.
2. Internal hydrant provided but found nonfunctional.
3. Terrace level Fire Pump capacity of 450 & 180 LPM provided but found nonfunctional.
4. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 54.