



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/2024/School/ 793

Dated: 28/11/2024

To

Rev. Fr. Savariraj (Principal)
Rosary Senior Sec. School at
Radio Colony, Kingsway Camp, Delhi-09

Sub:- Regarding renewal of fire safety certificate in r/o Rosary Senior Secondary School at Radio Colony, Kingsway Camp, Delhi-110009.

Sir,

Please refer to your letter received through online e-mail dated: 19.11.2024 on the subject cited above. In this connection this is to inform you the aforesaid building was inspected by the officers concerned of this department on 22.11.2024 in the presence of Mr. Anthony (Supervisor) to verify the status of the shortcomings already issued by this department vide letter No.F6/DFS/MS/2024/School/505 dated 07.08.2024 and status is as under: -

S No.	Shortcomings	Status
1.	Hose reel hose is provided but not functional and short in no's.	Complied
2.	Some hoses badly damaged, branch & coupling found short in no's.	Not Complied
3.	Terrace level fire pump capacity of 450lpm each found not functional and badly damaged condition. Fire service inlet at ground level found damaged condition	Complied
4.	Terrace level fire water tank capacity of 5000ltr each block found empty and is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.	Complied
5.	Exit, floor & lift signage's found removed at strategic locations in the school building.	Complied
6.	Electrical panel below in staircase needs to be removed/shifted in a safer place.	Not Complied
7.	Temporary tin shed constructed at A-block terrace for storage old furniture carpets & sofa seats is highly flammable needs to be removed.	Not Complied
8.	One staircase of both blocks from ground to terrace level found obstruct by combustible old damaged furniture material/ highly flammable & risk of life needs to be removed.	Not Complied

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.