

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/EH/2024/SZ/ 520

Dated: 27/11/2024

To

The Addl. Commissioner of Police (Lic/Unit),
1st Floor, P.S. Defence Colony,
New Delhi-110049.

Sub: Regarding issuance of FSC in r/o **M/s Ankara** located at First Floor, Property No 3, LSC Market, Masjid Moth, G.K New Delhi -110048

Sir,

This is in reference with **MFR Portal ID 2024042406037 dated 11/11/2024** on the subject cited above. In this connection, it is to inform you that the premise have been inspected by officer concerned of this department on 22/11/2024 in the presence of Mr. Sanjay (Manager) and to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. First aid hose reel provided but found not working.
2. Internal hydrant provided but found not working.
3. Fire fighting pumps are provided but found not working.
4. Exit signage's found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE