

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/Assembly/NDZ/2024/ 645

Dated: 29/11/2024

To

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre, New Delhi - 02.

Sub: - Regarding issuance of Fire Safety Certificate in respect of M/s Auditorium Block, NCDC, Plot No. 22, Sham Nath Marg, Civil Lines, Delhi.

Sir,

This has a reference to online application ID No. 10106527 dated 21.11.2024 received on the subject cited above. In this connection, it is to inform you that the above mentioned premises was visited by the team of officers concerned of this department on 26.11.2024 in presence of Mr. Jai Kumar, NBCC & Mr. RR. Meena, AE (MCD) and it was observed that building is comprised of Basement + Ground + 03 upper floors. During inspection, following shortcomings were observed:

1. Door size of auditorium having width of 1.5 m is provided against the requirement of 2.0 m.
2. Overhead water storage tank provided is 10,000 ltr. against the requirement of 20,000 Itrs.
3. Pressurization of lift lobby not provided.
4. Electrical panels in basement not protected by fixed fire fighting installation.
5. No. of seats in rows at 1 floor (balcony) are more than 14.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Virendra Singh)

Chief Fire Officer

Delhi Fire Service

Tel: 01123414333

Copy to:-

1. The Authorized Signatory,
NCDC Cell, Plot No. 22, Sham Nath Marg, Civil Lines, Delhi.


29/11