

c/10



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No. F6/DFS/MS/SZ/2024/ EN/514

Dated: 25/11/2024

To,

The Addl. Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit, Police Station,  
Defence Colony, New Delhi.

**Subject: - Issuance of Fire safety Certificate in r/o Big tree café Dwarka Located at Plot No. 15, 3<sup>rd</sup> floor, service centre, Sector – 20, Dwarka, New Delhi – 110075.**

Sir,

Please refer to online application No. 2024100415203 dated 28/10/2024 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the officers concerned from this department on 19/11/2024 in the presence of Mr. Dinesh Singh (Supervisor) from fire safety point of view.

During the course of inspection the following shortcomings were observed.

1. Automatic fire detection system found nonfunctional.
2. Manually operated fire alarm system found provided but nonfunctional.
3. Hose reel hose found not provided at terrace.
4. Hydrants found not provided.
5. Main Pump and stand by pump of 2280lpm & jockey pump of 180lpm s at ground found provided but non functional. The discharge capacity & head of all the pumps must be furnished.
6. Terrace fire pump of 450lpm capacity found provided but non functional.
7. Dimension & capacity of Underground fire tank & over head fire water tank not provided.
8. Exit signage found not provided at some places.
9. Construction work at ground level was found under progress. The exit passage must be kept free from any obstruction.

In view of the above shortcomings issuance of Fire Safety Certificate from fire safety point of view cannot be considered. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter.

(Atul Garg)  
Director  
Delhi Fire Service

*[Handwritten signature and date 25/11/24]*  
*[Handwritten initials 'elk' and date 20/11/24]*

Copy to: -

1. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.
2. The Manager, Big tree café Dwarka Located at Plot No. 15, 3<sup>rd</sup> floor, service centre, Sector – 20, Dwarka, New Delhi – 110075.