

0153

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ 94/698

Dated: 22/11/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s Vedas Heritage Guest House located at 8A/28, WEA Channa Market, Karol Bagh, New Delhi - 110005.

Sir,

Please refer to online application No. 2024102516146, dated 25/10/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 12/11/2024 in the presence of Sh. Ibrahim (Manager) from fire safety point of view.

During the course of inspection following shortcomings were observed:

1. The Smoke management System found removed in basement.
2. Hose reel hose found nonfunctional.
3. MOEFA & P A System found nonfunctional
4. Terrace pump of 450 lpm capacity found nonfunctional.
5. Exit signage found removed at some places

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Manager, M/s Vedas Heritage Guest House located at 8A/28, WEA Channa Market, Karol Bagh, New Delhi - 110005.
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi for information w.r.t. the use of the basement.