

C/64

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2024/701

Dated: 25/11/2024

To

The Addl. Commissioner of Police,  
Licensing Unit 1st Floor,  
P.S Defence Colony,  
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in r/o M/s Guest House J.P Inn located at 5/2, East Patel Nagar, New Delhi - 110008.**

Sir,

Please refer to online application No. 2024100615323, dated 29/10/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 21/11/2024 in the presence of Sh. Umesh Tiwari (Manager) from fire safety point of view.

During the course of inspection following shortcomings were observed:

1. Hose reel hose found nonfunctional.
2. CO detectors found removed.
3. P A System found removed
4. Terrace pump of 450 lpm capacity found nonfunctional.
5. Exit signage found removed at some places

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Manager, J.P Inn located at 5/2, East Patel Nagar, New Delhi - 110008.
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi for information w.r.t. the use of the basement.