

c/64

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2024/ 44/702

Dated: 26/11/2024

To

The Addl. Commissioner of Police,  
Licensing Unit 1st Floor,  
P.S Defence Colony,  
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in r/o M/s Guest House M/s Hotel Shimla Heritage located at Ground, 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> floor 7A/36, WEA Channa Market, Karol Bagh, New Delhi - 110005.**

Sir,

Please refer to online application No. 2024110516442, dated 05/11/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 21/11/2024 in the presence of Sh. Darmiyan Singh (Manager) from fire safety point of view.

During the course of inspection following shortcomings were observed:

1. Exhaust fans found removed in basement.
2. Terrace pump of 450 lpm capacity found nonfunctional on auto mode.
3. Exit signage found removed at some places
4. Seating arrangement was seen at Stilt floor and basement. The basement & stilt floor must be used as per UBBL.
5. One room at terrace was found being use for cooking.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

(Atul Garg)  
Director  
Delhi Fire Service  
o/c  
22/11/24

Copy to: -

1. The Manager, M/s Hotel Shimla Heritage located at Ground, 1<sup>st</sup>, 2<sup>nd</sup> & 3<sup>rd</sup> floor 7A/36, WEA Channa Market, Karol Bagh, New Delhi - 110005.
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi for information w.r.t. the use of the basement.