

e/52

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2024/ 699

Dated 22/11/2024

To,

The Manager,  
M/s Sirswal View Guest House,  
4076-77, Gali Kaseruwalan,  
Pahar Ganj, New Delhi

Sub: Regarding renewal of fire FSC in r/o Sirswal View Guest House located at 4076-77,  
Gali Kaseruwalan, Pahar Ganj, New Delhi

Sir,

This has reference to on line ID No. 2024102215992 dated 22/10/24, on the subject cited above, it is to inform you that the site was inspected by the officers concerned of this department on 14/11/2024 in the presence of Mr. Alam and observed that there is addition /alteration in the building and the following shortcomings were observed:-

1. Alternate staircase of 1.5 meter is required against the providing of 1.25 meter.
2. Corridor 1.8 meter is required against the providing of 1.20 meter.
3. Terrace tank of 5000 liter is required to be provided.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

  
(Ajul Garg)  
DIRECTOR  
Delhi Fire Service  
19/11

Copy to :-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.