

c/31

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/EH/2024/SZ/ 517
To

Dated: 25/11/2024

The Addl. Commission of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049

Sub: Regarding issuance of FSC in r/o M/s Third Wave Coffee (Unit of HEISETASSE BEVERAGES Pvt Ltd) at E -4, Kalkaji, New Delhi 110019

Sir,

This has reference to with **MHA Portal ID 2024110716552 dated 08/11/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 20.11.2024 in the presence of Ms. Champa (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are two staircases having width of 1.50 mtr & 1.40 mtr against the requirement of 1.50 mtr each.
2. The exit door having width of 1.50 mtr & 1 mtr against the required width of 1.50 mtr each as per UBBL 2016.
3. Fire Fighting pumps are not working.
4. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

qu e