

2/83

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2024/ 803

Dated: 04/12/2024

To,

The Principal,
Guru Teg Bahadur 3rd Century Public School,
C- Block, Mansarovar Garden,
New Delhi-110015.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Guru Teg Bahadur 3rd Century Public School Located at C- Block, Mansarovar Garden, New Delhi-110015.

Sir,

This is in reference to your letter no. nil, received through Outdoor diary No. 7183 dated 30/09/2024, on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 11/11/2024 in presence of Mrs Jaspritma kaur (Principal) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the said school is running in total four blocks (78 Class Rooms) A = G + 2 Upper Floors, B = G + 2 Upper Floors, C = G + 1 Admin Office, D = G + 1 Primary Wing, B & C blocks are connected at 1st Floor. Fire safety arrangements Such as Fire Extinguishers, First -Aid hose reels, Terrace pump, Over head water storage tank, etc. are provided. However the following Shortcomings were observed.

1. One staircase provided in D-Block having with of 1X1.30m, second staircase found Blocked.
2. Main fire pump of 450lpm is provided but not functional.
5. Exit Sinages are found removed.

In view of above Shortcomings the application for Renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier.

Yours faithfully,

(Atul Gang)
Director

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

2/83
03/12/2024