

d/145

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2024/SZ/ 706  
To

Dated: 03/12/2024

The Joint Commissioner of Police,  
Lic/Branch, 1<sup>st</sup> Floor, P.S Defence Colony,  
New Delhi 110049

Sub: Regarding issuance of FSC in r/o M/s "Hamilton Lodge" Guest House at S-153,  
Panchsheel Park, New Delhi-110017

Sir,

This is in reference with **MHA Portal ID- 2024110716548 dated 07/11/2024** on the subject cited above. In this connection, it is inform you that the premises have been inspected by officer concerned of this department on 26/11/2024 in the presence of Sh. Shivam (Manager) of the Guest House. During the inspection, it was observed that the guest house is running at Ground + 03 Upper Floor. The shortcomings observed are as below;

1. Smoke management system found removed at upper floors.
2. First aid hose reel provided but found not working.
3. MOEFA not working.
4. Terrace level fire fighting pumps provided but found not working.
5. Exit Signage found removed at some places.
6. The Wooden / Bamboo's, ruffling structure at entrance gate need to be removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

d/m