

c/67

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2024/ 91 | 710

DATED: 03/11/2024

To,
The Joint Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s Hotel Hill Palace Located at 14A/32, WEA, Karol Bagh, New Delhi-110005.

Sir,

Please refer to online application No. 2024110716532, dated 07/11/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 26/11/2024 in the presence of Sh. Manjeet Singh Negi (Manager) to see the compliance of the shortcomings communicated vide this office letter No. F.6/DFS/MS/GH/SZ/2024/542, dated 02/09/2024 and found that the shortcomings are still not fully complied.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter. In the absence of Fire Safety Certificate this guest house is not safe from fire safety point of view.

Yours faithfully,

(Ajul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi for information w.r.t. the use of the basement
2. The Manager, M/s Hotel Hill Palace Located at 14A/32, Channa Market, WEA, Karol Bagh, New Delhi-110005.

0-57

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ 41 | 542

Dated: 02/10/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s Hotel Hill Palace Located at 14A/32, WEA, Karol Bagh, New Delhi-110005.

Sir,

Please refer to online application No. 2024080712330, dated 07/08/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 24/08/2024 in the presence of Sh. Ranjeet Singh Negi (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Ventilation system not provided in common area.
2. CO Detectors found removed.
3. Hose reel hose found nonfunctional.
4. Terrace pump of capacity 900 lpm found nonfunctional & main valve found closed at terrace level.
5. Basement found closed could not be inspected.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service
02/10/24

Copy to: -

1. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi for information w.r.t. the use of the basement.
2. The Manager, M/s Hotel Hill Palace Located at 14A/32, WEA, Karol Bagh, New Delhi-110005.