

c/38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/ 524

Dated: 28/11/2024

To,

The Addl. Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi.

Subject: Renewal of Fire Safety Certificate from fire safety point of view in r/o M/s Kadimi Food Pvt Ltd. Located at 2nd floor, Plot No- 7, Sector – 11, Pkt – IV, Dwarka, New Delhi – 110075.


Sir,

Please refer to online application No. 2024110416366 dated 08-11-2024 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the officers concerned from this department on 25/11/2024 in the presence of Sh. Dilip Singh (Cashier) from fire safety point of view.

During the course of inspection the following shortcomings were observed.

1. Exit passage found not clear.
2. Hose reel hose & hydrants found nonfunctional.
3. Automatic sprinkler system found nonfictional.
4. Open able window provided in stairs found blocked.
5. Terrace pumps found nonfunctional.
6. Electric meter are installed in stair. The electric meters must be covered by MS boxes.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. Applicant may be directed to comply the shortcomings under intimation with this department for further consideration in the matter.


(Atul Garg)
Director
Delhi Fire Service
28/11/24

Copy to: -

1. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.
2. The Manager, M/s Kadimi Food Pvt Ltd. Located at 2nd floor, Plot No- 7, Sector – 11, Pkt – IV, Dwarka, New Delhi – 110075.