



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 801

Dated: 03/12/2024

To,

The Principal
M.C. Primary School, F-Block,
Single Storey, Vijay Nagar, Delhi-09.

Sub:- Regarding issuance of fire safety certificate in r/o M.C. Primary School located at F- Block, Single Storey, Vijay Nagar Delhi-110009.

Sir,

Please refer to your letter no. nil dated 19.11.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 19.11.2024 to verify the fire safety arrangements provided therein as per the NBC Part-IV/UBBL-2016. At the time of inspection Smt. Anita Arya (Incharge) was also present at site and said building was comprised of ground & 02 upper floors only. Your request for FSC is rejected under Rule 35 due to following shortcomings.

1. There is two staircase provided width of 1.50m & 1.20m against the requirements of 1.50m each and needs both staircase continues from ground to terrace level.
1. Fire extinguishers provided is 03 nos. against the requirement of 06 nos.
2. Hose reel hose not provided.
3. Terrace level fire pump capacity of 450 LPM is not provided.
4. Terrace level fire water tank capacity of 10,000ltr is not provided.
5. Exit & floors signage's not provided at strategic location in the school building.
6. Standby power supply is not provided.
7. Electrical panel below in staircase needs to be removed/shifted in a safer place.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director
Ph: 011-23414000

Copy to:-

1. The Dy. Director, Education Department, Civil Line Zone, 16 Rajpura Road, Delhi.

Handwritten signature and date 29/12