



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/11/24
आज्जादीय
अमृत महोत्सव

No. F6/DFS/MS/BQT/SZ/2024/ 133

Dated: 03/12/2024

To

The Joint Commissioner of Police,
Office of Joint Commissioner of Police: Licensing,
1st Floor, P. S Defence Colony, New Delhi.

Sub: -Regarding grant of Fire Safety Certificate in r/o M/s Moon Light Banquet Hall located at L-5, Near Khalilullah Masjid, Batla House, Jamia Nagar, New Delhi-25.

Sir,
with reference to the etl.mcdonline application ID no. 2024111116666 on the subject cited above, it is informed that the said Banquet hall was inspected officer concerned from this department on 25.11.2024 in the presence of Mr. Javed (Manager) and it was observed that the Banquet hall is running at Ground floor & half portion of 1st floor of the building which is comprised of **Ground + 04 upper floors**. During the inspection following shortcomings were observed:

1. Main and alternate exit door width of 2.0 meters and 1.50 meters respectively has not been provided at ground floor.
2. Main staircase & alternate staircase of 1.50 meters width each has not been provided from 1st floor to ground floor.
3. Fire Check Door (FCD) has not been provided in kitchen and kitchen has not been segregated from ear exit by fire resistant construction.
4. First Aid Hose Reel has not been provided.
5. Manual Operated Electrical Fire Alarm (MOEFA) system has not been provided.
6. Internal hydrant system has not been provided.
7. Fire pump having capacity 450 LPM & head 40 m has not been provide.
8. Overhand tank capacity of 20,000 liters for firefighting has not been provided.
9. Exit signage has not been provided.
10. Standby power supply has not been provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

27/11/24

Copy to:-

1. The Commissioner, MCD, Dr. SPM Civic Centre, JLN Marg, New Delhi.
2. The Executive Engineer (Building), MCD, Jal Vihar, Lajpat Nagar, New Delhi-24- To verify the height of the building under intimation to this department.