

C-89

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001**

No. F6/DFS/MS/WZ/2024/BNQT/132

Dated: 29/11/2024

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[adlcp.lic-dl@nic.in](mailto:adlcp.lic-dl@nic.in)

Sub: Renewal of Fire Safety Certificate in respect M/s. Rain tree Locate at A-7-8, Ground Floor, Kailash Park, Main Najafgarh Road, Near Moti Nagar, New Delhi-110015.

Sir,

Please refer to the online application ID no. 2024110616480 dated 06/11/2024, received through MHA portal on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 22/11/2024 in the presence of Sh. Jitender Gangwal to check the fire safety arrangements provided in the building.

During inspection, it was observed that the said Banquet Hall is running at ground floor in a building comprised of basement, ground, three upper floors only, was issued FSC vide letter No. F6/DFS/MS/BNQT/WZ/2021/527 dated 26/10/2021 for ground floor only. However the following shortcomings were observed.

1. First Aid Hose reel is provided but not functional.
2. MOEFA is provided but not functional.
3. Terrace level main fire pump capacity of 450lpm is provided but not functional.
4. Over head water storage tank 2000ltrs is provided against requirement of 10,000ltrs.
5. Exit signages are found removed.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The Licensing authority /statutory authority may take suitable necessary action as deemed fit.

Yours Faithfully,

  
(Atul Garg)  
Director

Copy to: -

1. The Owner/Occupier M/s. Rain tree Locate at A-7-8, Ground Floor, Kailash Park, Main Najafgarh Road, Near Moti Nagar, New Delhi-110015.
2. The Dy. Health Officer, West Zone, South Delhi Municipal Corporation, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id:- ([dhowest\\_zone@gmail.com](mailto:dhowest_zone@gmail.com))

  
25/11/2024