



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7
आजादी का
अमृत महोत्सव

c/80

No. F6/DFS/MS/WZ/2024/ 799

Dated:- 03/12/2024

To,

The Principal,
Govt. Sarvodaya Kanya Vidyalaya (ID-1617005),
Ranhaul, Delhi-110041.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of Govt. Sarvodaya Kanya Vidyalaya, located at Ranhaul, Delhi-110041.

Sir,

Please refer to your email dated 16/11/2024, on the subject cited above. In this connection, it is to inform you that the above said school building have been re-inspected by the officer concerned of this department on 26/11/2024 in the presence of Sh. Vijay Kumar Pandey (Estate Manager). During inspection, it has been observed that the school building is comprised of 02 blocks – Ground + 03 Upper Floors. However, the following shortcoming has been observed:-

1. First Aid Hose Reels found non-functional.
2. Terrace fire pump found non-functional.

In view of the above shortcomings, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

(Atul Garg)
Director

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.

29/11/2024
29/11/24