

c/70

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2024/ 708

Dated:- 03/12/2024

To

The Manager
M/s Shree Balaji Dx. Guest House,
2204, Raj Guru Road, Chuna Mandi,
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M/s Shree Balaji Dx. Guest House at 2204, Raj Guru Road, Chuna Mandi, Pahar Ganj, New Delhi.

Sir,

This has reference to online id no. 2024103016305 dated 30.10.24, on the subject cited above. In this connection, it is to inform you that the site was inspected by the officer concerned of this department on 22/11/24 in the presence of Mr. Jogender and following shortcomings were observed:-

1. Hose reel & pump found nonfunctional.
2. Stand by power supply not provided.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.