

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2024/ Sch | 806

Dated:- 05/12/2024

To,

The Principal,
DAV Public School,
Reserve Bank Enclave,
Paschim Vihar, New Delhi-110063.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of DAV Public School, located at Reserve Bank Enclave, Paschim Vihar, New Delhi-110063.

Sir,

Please refer to your email dated 28/11/2024, on the subject cited above. In this connection, it is to inform you that the above said school building have been re-inspected by the officer concerned of this department on 30/11/2024 in the presence of Sh. Dharam Prakash (Teacher). During inspection, it has been observed that the school building is comprised of Ground + 01 Upper Floors. However, the following shortcoming has been observed:-

1. In most of the class room student's strength is more than 45 students and class rooms have only single exit/entrance door against requirement of 02 nos. exit/entrance door.
2. Overhead water storage tank found reduced to 2,000 ltrs against requirement of 2500 ltrs. & domestic connection drawn to be removed.
3. Staircase terrace door found locked during occupied of the school.
4. One room found constructed on terrace floor to be dismantled or to be sealed by brick wall. And availability of unauthorized LPG cylinder with sigri shows, same is using as residential.
5. Corridor blocked by erecting a temporary room with wooden & aluminum partition to be removed.

In view of the above shortcomings, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,

(Atul Garg)
Director

Copy to:-

3/12/24
05/12/24