



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/BP/2024/ 647

Dated: 03/12/2024

To

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
8th Floor, Civic Centre, JLN Marg,
New Delhi- 110002.

Sub:- Rejection of building plans from fire safety point of view in r/o Industrial / storage building at Plot No. 121, Pocket-E, Sector-2, DSIIDC Bawana Industrial Area, Delhi.

Sir,

With reference to request ID no. 10119770 dated 24.11.2024 on the subject cited above; it is informed that the referred online building plans in respect of proposed construction of Industrial / Storage Building at Plot No. 121, Pocket-E, Sector-2, DSIIDC Bawana Industrial Area, Delhi were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcomings were observed:-

1. There is difference in information provided in CAF and the plans submitted.
2. Fire prevention & fire safety measures are not proposed as per NBC-2016, Part-IV/UBBL-2016.

In view of the above, the building plans are rejected with a request to resubmit plans after rectification of above shortcomings for further consideration in the matter.

Yours faithfully,

(Atul Garg)

Director


e H.