

2147

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2024/School/805

Dated: 05/12/2024

To,  
The Principal,  
Sarvodaya Kanya Vidyalaya,  
Ranjit Nagar, New Delhi - 110008.

**Subject: Renewal of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya Located at Ranjit Nagar, New Delhi - 110008.**

Sir,

Please refer to your letter no. Email, dated 11/11/2024 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 03/12/2024 in presence of Sh. PP Prince (Estate Manager) from fire safety point of view.

During the course of inspection the following shortcomings were observed.

1. Hose Reel Hoses found nonfunctional & nozzle found missing at some places.
2. Terrace pump found non functional.
3. Exit signage's found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)  
Director  
Delhi Fire Services

Copy to:-

The, Directorate of Education Old Secretariat Delhi – 110054.

e/c



3/12/24