



No. F6/DFS/MS/GH/NDZ/2024/ 716

Dated: 05/12/2024

To,

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> floor, Police Station Defence Colony,  
New Delhi – 110024.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Adimurti Foods and Beverages Pvt. Ltd located at Property no. 1/49, First, Second and Third floor Lalita Park, Laxmi Nagar, Main Vikas Marg, Delhi - 110092.**

Sir,

This has a reference to MHA application No. 2024110616481 dated 06.11.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 26/11/2024 in the presence of Mr. Arjun Munjral (Owner) and observed that building comprised of Basement (Closed) + Ground floor (Vacant) + three upper floors only. **(Guest House running on first, second & third floors only)**

**Following shortcomings were observed during time of inspection:**

1. Two stair case of width 1.45 meters & 1.40 meters are provided instead of required width 1.50 meters each.
2. Fire check doors not provided.
3. Smoke Management System not provided in upper floors.
4. Carbon monoxide detectors found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. Mr. Arjun Munjral (Owner), Adimurti Foods and Beverages Pvt. Ltd Property no. 1/49, First, Second and third floor Lalita Park, Laxmi Nagar, Main Vikas Marg, Delhi - 110092.