



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



C/22

No.F6/DFS/MS/2024/Hospital/ 650

Dated 04/12/2024

To,

Dr. Aseem Taneja (OSD)
Burari Hospital Govt. of NCT of Delhi.
Kaushik Enclave, Burari, Delhi-110084.

Sub:- Renewal of fire safety certificate in r/o Burari Hospital located at Kaushik Enclave, Burari, Delhi-110084.

Sir,

This has reference to your letter no-F.3(9)20-21/BH/000292/PWD/FIRE/8664 dated: 08.08.2024 on the subject cited above. In this connection this is to inform you the above mentioned site was visited by the officer concerned of this department on 18.11.2024 & 23.11.2024 to verify the fire safety arrangements installed in the building. At the time of inspection Sh. Kuldeep Sharma (AE. Elec.) & Sh. Mohd. Iqbal (AE. Elect.) PWD along with other members of PWD was also present at site. During the course of the inspection it is observed that the building is comprised of two level basement, ground & 07 upper floors. Your request for FSC is rejected under Rule 37 due to following shortcomings:-

1. Some fire check doors found damaged.
2. Staircase pressurization system not functional.
3. Smoke management system not functional.
4. Hose reel hose nozzle are missing in all upper floors.
5. Sprinkler fire pump & Water curtain pump are not on auto mode.
6. Some internal hydrant coupling, hoses, branch & wheels for opening valve found missing.
7. Exit signage's found removed at some places.
8. Pressurization of lift shaft, lift lobby, lift grounding switch & communication system in lift car found provided but not functional.
9. Refuge area located at sixth floor found locked.

Keeping in view of above shortcomings, the said building is not safe from fire safety point of view & renewal of Fire Safety Certificate cannot be considered at this stage. Hence, you are advised to comply all the shortcomings at the earliest under intimation to this department. Any loss of life and property untoward mishap due to non-compliance of the fire safety measures in the event of fire and other emergency the management is solely responsible.

Yours faithfully

(Atul Garg)

Director

Ph.-011-25104000

Copy to:-

1. Sh. Mohd. Iqbal, AE (E), Dr. Baba Sahab Ambedkar Hospital, Sector-6, Rohini, Delhi-85.

3/12/2024