



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2024/ 717

Dated: 05/12/2024

To,  
The Manager,  
M/s East Inn Hotel,  
E – 364, Nirman Vihar, Vikas Marg,  
Delhi – 110092.

**Subject: - Regarding grant of Fire Safety Certificate in r/o M/s East Inn Hotel located at E – 364, Nirman Vihar, Vikas Marg, Delhi - 110092.**

Sir,  
This has a reference to your MHA Portal application No. 2024110616503 dated 07/11/2024 on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 19/11/2024 in the presence of Mr. Ansar Ahmed (Manager) and observed that building comprised of **basement + ground + mezzanine plus three upper floors**, Basement (Store), Ground floor – (Shops & Reception), Mezzanine (Office), 1<sup>st</sup> floor - (06 guest rooms), Second floor - (05 guest rooms), total 11 guest rooms.

**Following shortcomings were observed during time of inspection:**

1. Carbon monoxide detectors not provided.
2. Fire check door not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

0/L DELHI FIRE SERVICE  
@

Copy to:-

1. The Joint Commissioner of Police (Lic.), 1<sup>st</sup> floor, Police Station Defence Colony, New Delhi - 110024, w.e.f. - MHA portal ID - 2024110616503 dated 07/11/2024.