



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/27
7/5
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/Hospital/NDZ/2024/ 646

Dated: 02/12/2024

To,

The Director,
M/s Monga Medical Centre
Plot No. J - 10, Krishna Nagar,
Delhi - 110051.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Monga Medical Centre located at Plot No. J - 10, Krishna Nagar, Delhi - 110051.

Sir,

This has a reference to your outdoor dairy no. 8405 dated 28/10/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 21/11/2024 in the presence of Dr. V. K. Monga and observed that building comprised of Basement + stilt (Parking) & Reception + Upper ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. Pump is not on auto mode.
2. Exit & floors Signage's not provided at strategic location in the building.
3. Lift signage's not provided.
4. There is a LPG kitchen running on terrace.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Manager, M/s Monga Medical Centre located at Plot No. J - 10, Krishna Nagar, Delhi - 110051.
2. The Exective Engineer (Bldg), Municipal Corpration of Delhi, Plot no. 419, Patparganj Industrial Area, Delhi -110092.
3. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3rd floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi - 110032.