

c/42

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/2024 | 712

Dated:- 04/12/2024

To,

The Manager  
M/S Raman Palace Guest House,  
1310-1311- A, Sangatrashan Bazar,  
Pahar Ganj, New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o Raman Palace Guest House at 1310-1311-A, Sangatrashan Bazar, Pahar Ganj, New Delhi.**

Sir,

This has reference to on line ID No. 2024111016647 dated 10/11/2024, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 22/11/24 in the presence of Manager and following shortcomings were observed:

1. CO- detector & Exhaust system are not provided.
2. Hose reel & pump found nonfunctional.
3. Building plan is not signed by owner and section/elevation of building plan is also required to be uploaded on the portal.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,

  
(Anil Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:

Addl. Commissioner of Police ( Lic), 1st floor, Defence Colony Police Station, New Delhi.