

2/43

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI- 110001**

No. F6/DFS/MS/School/2024/SZ/ 813

Dated: 10/12/2024

To,

The Vice Principal,  
Sarvodaya Kanya Vidyalaya,  
B-Block, Janak Puri, New Delhi-110058.

**Sub: -Regarding renewal of "FSC" from fire safety point of view in r/o Sarvodaya Kanya Vidyalaya at B-Block, Janak Puri, New Delhi-110058.**

Sir,

Please refer to your letter received through online email Id [skv.janakpuri@gmail.com](mailto:skv.janakpuri@gmail.com) dated 20.11.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 02.12.2024 in the presence of Mrs. Nidhi Kumari (V. Principal), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school building having two blocks namely old block comprised of ground plus two upper floors and new block comprised of ground plus three upper floors, and following shortcomings were observed: -

1. Hose reels/hydrant provided but found not functional in both blocks.
2. Terrace pump of 450 LPM×2 (new blk) & 450 lpm (old blk) provided but found not functional in auto mode.
3. Exit Signes are found removed at some places in both blocks.

In view of the above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.