



c/5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/2024/EH/543  
To

Dated 11/12/2024

The Joint Commissioner of Police/ Lic,  
1<sup>st</sup> Floor, Licensing Unit, Police Station  
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s 3 Kings Café And Lounge located at  
Property No-2/10, First Floor, Roop Nagar, Delhi-110007.

Sir,

This has reference to online mha portal I'd. No. 2024090914009 dated: 18.11.2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 03.12.2024 in the presence of Mr. Sunpreet Singh (Partner) to verify the fire safety measures installed in the building and observed that the building is comprised of ground & 03 upper floors but restaurant is running at first floor. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 Smoke management system is not provided.
- 2 Hose reel hose is provided but not functional.
- 3 MOEFA system is not provided.
- 4 Internal hydrant is provided but not functional.
- 5 Terrace level fire pump capacity of 450lpm is not provided.
- 6 Terrace level fire water tank capacity of 20,000ltrs is not provided.
- 7 Exit signage's is not provided.
- 8 Standby power supply is not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of restaurant is at your own risk & responsibility.

Yours faithfully

  
(Atul Garg)  
Director  
Ph: 011-23414000

6/12/24