

e/235

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2024/SZ/ 798

Dated: 03/12/2024

To,

The Chairman,  
Brilliance School, RZ-23, X-Block,  
New Roshanpura, Najafgarh, New Delhi- 110043.

**Sub: -Regarding Complaint against violence of fire safety norms at Brilliance School at RZ-23, X-Block, New Roshanpura, Najafgarh, New Delhi- 110043.**

Sir,

This has reference to complaint letter No. Nil dated 10.10.2024, received from Sh. Karamvir Singh R/o Flat No. 2A, IB-Block, Phase-1, Ashok Vihar, New Delhi- 110052, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 13.11.2024 in the presence of Ms. Arti (Incharge), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the Earlier FSC was issued vide letter no. F.6/DFS/MS/School/2022/SZ/1313 dated 14.12.2022 in r/o Brilliance School at RZ-23 & RZ-24, X-Block, New Roshan Pura, Najafgarh, New Delhi- 110043. But now the school building floor-wise divided by wall in two portions, school running only RZ-23 and RZ-24 is not the school property and school building comprised of basement, ground and three upper floors (third floor used for owner residence, The building constructed before 2015, and having following shortcomings were observed: -

1. Only one staircase having width of 1.52 m found provided in the school building against requirement of two staircases with width of 1.50 & 0.75 m.
2. Overhead water storage tank capacity of 5,000 ltrs. found provided against requirement capacity of 15,000 ltrs.

In view of the above, fire safety certificate cannot be considered at this stage. Therefore, the FSC issued vide letter no. F.6/DFS/MS/School/2022/SZ/1313 dated 14.12.2022 is withdraw with immediate effect. You are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

  
(Anil Garg)  
Director  
Delhi Fire Service

Copy to: -

1. Sh. Karamvir Singh, Flat No. 2A, IB-Block, Phase-1, Ashok Vihar, New Delhi-52,  
Mob. No. 9718994311. Email Id [karamvirsvb@gmail.com](mailto:karamvirsvb@gmail.com).
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.