

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/EH/2024/SZ/ 535  
To

Dated: 10.../12.../2024

The Addl. Commissioner of Police,  
Lic Branch 1<sup>st</sup> Floor PS Defence Colony,  
New Delhi- 110049

Sub: Regarding issuance of FSC in r/o M/s Connaught Plaza Restaurant private Limited  
McDonald's Family Restaurant located at S-25, Green Park Main Market, New Delhi  
110016.


Sir,

This has reference to your **MCD Portal ID 2024110616524 dated 07/11/2024 & 2024110616516 dated 06/11/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 04.12.2024 in the presence of Mr. Amit (Guard) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Ground level Fire fighting pump capacity 2280 LPM, Diesel Engine Pump 2280 LPM and Jockey Pump 180 LPM not provided.
2. Exit signage not provided at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

  
6/12/2024  
(ATUL GARG)  
For DIRECTOR  
DELHI FIRE SERVICE  
olw c