



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5  
साजादी का  
अमृत महोत्सव

No. F6/DFS/MS/EH/NDZ/2024/ 533

Dated: 06/12/2024

The Joint Commissioner of Police (Lic.),  
First Floor, P.S Defence Colony,  
New Delhi - 110024.

**Sub: - Regarding grant of Fire Safety Certificate in r/o Ms Mr. Crust Bakers located at A - 18, Ground floor, Guru Nanak Pura, Laxmi Nagar, Delhi - 110092.**

Sir,

This has a reference to your application No. 2024111316763 dated 14.11.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 28.11.2024 in the presence of Mr. Shivam (Manager) and observed that building comprised of Basement (Vacant), Ground plus three upper floors (1<sup>st</sup> & 2<sup>nd</sup> & 3<sup>rd</sup> OYO Guest House) (Restaurant is running on Ground floor of the building)

**Following shortcomings were observed during time of inspection:**

1. Overhead tank of 10,000 liters capacity is provided against the requirement of 20,000 liters.
2. Exit Signage not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. Ms Mr. Crust Bakers at A-18 G.F, Guru Nanak Pura, Laxmi Nagar, Delhi - 110092.