

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2024/ 658

DATED: 10/12/2024

To,

Sh. Rajesh Aggarwal,
Metro Bhawan, Fire Brigade Lane,
Barakhamba Road, New Delhi - 110001.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Delhi Metro Rail Corporation Ltd. Underground metro station Located at Palam Metro Station Line -8, New Delhi.

Sir,

Please refer to letter No. DMRC/O&M/Fire/NOC/L—8/2024/11/04 dated 05/11/2024 on the subject cited above. In this connection it is to inform to you that the above said premises has been inspected by the officer concerned of this department on 05/11/2024 in presence of Sh. Bhirgu Fukan (Asst. Manager/Fire) from fire safety point of view.

During the course of inspection followings shortcoming were observed:-

1. Staircases found locked at some places.
2. Fire Check Doors are found kept under electronic locks/ bolt/ locked at some places. It must be kept free from lock & keys/ bolts.
3. Smoke exhaust system found nonfunctional on auto mode.
4. Fire Hydrant cabinets were found kept under lock & key.
5. Exit signage found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The DGM (Operation), Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi – 110001.
2. The Manager, Delhi Metro Rail Corporation Ltd. Underground metro station Located at Palam Metro Station Line -8, New Delhi.