

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2024/ 661

DATED: 10/12/2024

To,

The Authorized Signatory
Dr. B.L. Kapur Memorial Hospital (A unit of Lahore Hospital Society)
Pusa Road, New Delhi - 110005.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Dr. B.L. Kapur Memorial Hospital (A unit of Lahore Hospital Society) Located at Pusa Road, New Delhi - 110005.

Sir,

Please refer to your later no BLK/MS/2024/Nov/21 dated 05/11/2024 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officers concerned of this department on 26/11/2024 in presence of Sh. Pursotam Dutt (Security Incharge) from fire safety point of view.

During the course of inspection followings shortcoming were observed:-

1. Six meter wide internal road around the building found encroached.
2. Fire check door closers found removed at some place.
3. Smoke exhaust system found nonfunctional in basement.
4. Automatic fire detection & alarming system found non functional.
5. MOEFA found nonfunctional.
6. Exit signage's found removed at some places
7. Pressurization of lift shaft & lift lobby found nonfunctional.
8. Communication system in lift car found nonfunctional.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation with this department for further consideration in the matter.

Copy to:-

1. The Directorate General of Health Services, F-17, Arjun Gali, Karkardooma, Anand Vihar, New Delhi - 110032.

(Atul Garg)
(Director)
Delhi Fire Service
o/c
10/12/24