

01/13

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/ 44 | 721

Dated: 10/12/2024

To

The Addl. Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in r/o M/s Guest House M/s Hotel Jyoti Deluxe located at Ground, 1st, 2nd & 3rd floor 4/68, WEA Saraswati Marg, Karol Bagh, New Delhi - 110005.

Sir,

Please refer to online application No. 2024111216699, dated 17/11/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 04/12/2024 in the presence of Sh. Mahipal Singh (Manager) from fire safety point of view.

During the course of inspection following shortcomings were observed:

1. Fire Check Doors were not found installed as per UBBL.
2. PA system found nonfunctional.
3. Terrace pump found nonfunctional on auto mode.
4. Exit signage found removed at some places

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

(Atul Garg)
Director
Delhi Fire Service

etc

Copy to: -

1. The Manager, M/s Hotel Jyoti Deluxe located at Ground, 1st, 2nd & 3rd floor 4/68, WEA Saraswati Marg, Karol Bagh, New Delhi - 110005.
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.