



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F.6/DFS/MS/BP/2024/ 654

Dated: 06/12/2024

To,

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station, Defence Colony,  
New Delhi.

Sub:- Rejection of proposal of installation of MS/HSD/CNG Retail Outlet at Khasra No. 5/11, 5/12, on Karala-Mundka Road, Madanpur Dabas, Delhi-110081.


Sir,

With reference to letter no. F.7/Pet./1283/2024/426/Joint CP/Lic.(Expl.), dated 11.10.2024 on the subject cited above; it is informed that the said proposal was scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcomings were observed:-

1. The complete building including firefighting arrangements, compressor details, dispenser details of etc. are not provided in the drawing.

In view of the above, the building plans are rejected with a request to resubmit plans after rectification of above shortcomings for further consideration.

Yours faithfully,

  
(Dr. S. K. Tomar)  
Dy. Chief Fire Officer

Copy to:-

Ms. Anju Jai Misra, General Manager,  
Delhi Retail, Hindustan Petroleum Corporation Ltd.,  
6, 7, 8<sup>th</sup> Floor, North Tower, Scope Minar, District Centre,  
Laxmi Nagar, Delhi-110092