

C-36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/Hospital/SZ/2024/2676

Dated: - 11/12/2024

To,

The Director,
M/s. Khanna Hospital, C-2/236,
Janak Puri, New Delhi- 110058.

Sub.: - Regarding issuance of FSC from fire safety point of view in r/o M/s. Khanna Hospital at C-2/396, Janak Puri, New Delhi- 110058.

Sir,

Please refer to your letter No. Nil, dated 26.11.2024, on the subject cited above. In this connection it is to inform you that the above said Hospital building have been inspected by the officer concerned of this department, in presence of Dr. Vivek Khanna, on dated 03.12.2024, to check the status of the shortcomings already pointed out by this department vide letter No. F6/DFS/MS/Hospital/2024/SZ/260 dated 13.05.2024. During the course of inspection, it was observed that the shortcomings are not fully complied.

In view of the above, issuance 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter and running hospital in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

The Directorate of Health Services, M.O./C Nursing Home Cell, S-1, School Block,
Shakarpur, New Delhi-110092.

: -for necessary action please.

13

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/Hospital/2024/SZ/ 260

Dated: 13/05/2024

To,

The Director,
M/s Khanna Hospital,
C-2/396, Janakpuri, New Delhi-110058.

Sub: - Regarding issuance of Fire Safety Certificate in r/o. M/s Khanna Hospital, situated at C-2/236, Janakpuri, New Delhi- 110058.

This has reference to your Letter No. Nil 'J' dated Nil, on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the hospital on 03.05.2024 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Sh. Vivek Khanna (M.D.) was present and it was observed that the hospital building is comprised of basement, ground plus three upper floors and have following shortcomings.

1. 02 staircase having width of 1.40 & 1.26 m found provided in basement and 02 staircase having width of 1.40 & 1.90 to 2.0 m found provided at ground floor to terrace level against requirement of 02 staircase having width of 2.0 & 1.50 m in basement to terrace level.
2. Fire check doors found not provided.
3. At third floor fire escape route found blocked (through a room).
4. Door width of 1.38 m found provided against required door width of 2.0 m.
5. Hose reels/hydrant found provided but not functional.
6. Heat/smoke detectors should be extended in left out area.
7. Sprinkler system should be extended in left out area.
8. Fire pumps found provided but not functional.
9. Exit Signes found not provided.
10. Fire Cartain found not provided in lift landing area.

Keeping in view of above, issuance of Fire Safety Certificate can-not be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Aml Garg)
Director

Delhi Fire Service

Copy to:-

1. MS, Nursing Homes, DGHS, Govt of NCT of Delhi, S-1, 3rd Floor, School Block, Shakarpur, Delhi-110092.