

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2024/SZ/ 719
To

Dated: 10/12/2024

The Joint Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Regarding issuance of FSC in r/o M/s The Orion Elite (A Unit of Strengthening India Pvt Ltd) located at H-3, Green Park Extension New Delhi 110016.

Sir,

This has reference with **MCD Portal ID 2024111116668 Dated 11/11/2024** on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 04/12/2024 in the presence of Mr. Anus Siddhique to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. The width of corridor shall be 1.50 mtr for single loaded and 1.80 mtr for double loaded as per clause 7.11.2 of UBBL 2016.
2. Smoke ventilation system not provided in the building as per clause 7.31 of UBBL 2016.
3. Overhead tank capacity 5,000 ltrs provided against the required capacity 10,000 ltrs.
4. Exit signage found not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

atn