



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2024/SZ/ 676

Dated: /6/12/2024

To

Ms. Ajeet Cour,
Padma Shri (Founder president),
Academy of Fine Arts & Literature,
4/6, Siri Fort Institutional Area,
New Delhi-110049

Sub: Regarding issuance of Fire NOC in r/o "Academy of Fine Arts & Literature" located at 4/6, Siri Fort Institutional Area, New Delhi-110049

Sir,

This has reference to your letter received through outdoor diary No. 7772 dated 14/10/2024. In this connection, the premise was inspected by the officer concerned of this department from fire & life safety point of view on dated 23/10/2024 in the presence of Sh. Bhupinder Singh & Jatinder Singh. During course of inspection, the shortcomings observed are as below.

1. Fire Check Door to segregate upper floor from basement found removed.
2. First-aid hose reel provided found non-functional.
3. Terrace level fire pump found non-functional.
4. Underground water storage tank found encroached by constructing room above the tank.
5. Exit signages found removed.
6. Additional rooms found constructed at grade level in the rear portion of the building.
7. LPG cylinders found stored in rear portion of the building.

In view of the above shortcomings, the application for issuance of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

ALSR

Copy to: -

1. The Executive Engineer (Bldg.), Municipal Corporation of Delhi, Lajpat Nagar-IV, New Delhi-110024