



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2024/ 819

Dated: 11/12/2024

To

The Chairman,  
Ahlebait Public School (Run by Ahlebait Trust),  
B-5, Shaheen Bagh, Jamia Nagar,  
New Delhi-25.

**Sub:-** Regarding issuance of Fire Safety Certificate in r/o Ahlebait Public School (Run by Ahlebait Trust) located at B-5, Shaheen Bagh, Jamia Nagar, New Delhi-25.

Sir,

With reference to the letter bearing outdoor diary no. 7018 dated 25.09.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 04.12.2024 in the presence of Mr. Syed Mohammad Askari (Chairman) and it was observed that the building is comprised of Basement + Upper Ground + 03 upper floors. During the inspection following shortcomings were observed:-

1. Clear width of one staircase is not meeting the requirements of 1.5 meters.
2. First aid hose reels found non functional.
3. Automatic sprinkler system has not been provided in the basement.
4. Fire pump of 900 LPM with head 40 m has not been provided.
5. Overhand tank capacity of 15,000 liters for firefighting has not been provided.
6. Exit signage has not been adequate.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

06/12/24

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.