

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**



No. F. 6. / DFS / MS / BP /CGHS/2024/ 675

Dated: 16 /12/2024

To,  
The Executive Engineer, (Bldg) HQ,  
Municipal Corporation of Delhi,  
9<sup>th</sup> Floor, Civic Centre,  
Minto Road, New Delhi-110002.

**Sub: Online building plans belonging to Bharat Jagriti CGHS Ltd., Plot No. 22 Sector-12, Dwarka, New Delhi for addition and alteration.**

Sir,

Please refer your online ID No. 10119669 dated 09.12.2024 on the subject cited above. In this connection it is to inform you that the referred online building plans have been scrutinized by this department from life/fire safety point of view and observed following shortcomings:

1. **6.0 meter wide fire tender movement road, all around the high rise buildings, is not marked on the plan as per old sanctioned vide letter No. F.6/MS/DFS/CGHS/2001/911 dated 18.05.2001.**

Therefore, plans are rejected.

Yours faithfully

  
(ATUL GARG)  
DIRECTOR

Ph. 011-23414000

